



## FYLLINGINSTRUKSJON

CO<sub>2</sub> apparater

Presto K2, K5

**Kontroll:**

Utføres i.h.t. NS 3910  
på følgende måte:

Apparatets vekt fylt, uten slange med trakt, fremkommer ved å legge sammen tara og CO<sub>2</sub> fyllingen. Disse vekter står stemplet på beholderen. Hvis mere enn -5% av CO<sub>2</sub> innholdet mangler skal apparatet omlades.

**Omladning:**

For omladning sendes apparatet til oss eller nærmeste forhandler.

**Data:**

Oppbevaringstemperatur fra -30°C til +60°C.  
Funksjonsdyktig fra -30°C til +60°C.

**Garanti:**

Produsenten har fem års garanti når det gjelder material- og produksjonsfeil.

Produsert i.h.t. NS EN3.

Trykkpåkjennte deler  
tillfredsstiller krav i  
direktiv 97/23/EC. (PED)

**Control:**

According NS 3910  
as follows:

Weight the extinguisher without hose and discharge horn. If the full weight (embossed on the cylinder) has decreased more than -5%, the extinguisher must be recharged.

**Recharging:**

For recharging send the extinguisher to us or a dealer.

**Data:**

Functionability from -30°C to +60°C.

**Warranty:**

The producer warrants that the unit is free from defects in material and fabrication under normal use and service for five years.

Produced according NS EN3.

Equipment under pressure is corresponding to requirement according Directive 97/23/EC. (PED)

CE-0409

Direktiv  
97/23/EC  
(PED)

EN 3

**Presto Brannteknik A/S**

UN.1044

Postboks 1096, NO-4095 STAVANGER

98411-0501